

## SolarInnovate Energy Solutions

# EAST uninterruptible power supply ups standard



## Overview

---

The product has been tested according to standard EN 62040-1: 2008+A1: 2013. EUT is designed for altitudes not exceeding 2000m. How safe is the ups?

A risk of injury is unlikely for the service personnel. The UPS is designed with only screwed enclosure parts. No component access during operation mode necessary. No servicing in operation mode necessary. No hazardous moving parts. The capacitors provided can produce energy level way below 20 joules.

Is backfeed protection provided external to the ups AC input line?

Backfeed protection was provided externally to the UPS in the a.c. input line. UPS. UPS. SELV limits are not exceeded under normal condition. Voltages under normal conditions (V) . . . . Within SELV limits. (See appended table 5.2.1) Voltages under fault conditions (V) . . . . . Within SELV limits.

Where is UPS battery located?

After rubbing test by water and petroleum spirit, the label still easily discernible, indelible and legible. No removable parts. Operator access with a tool. . . . . Pluggable type A, UPS battery is located in battery compartment.

What voltage does an ups SCR need?

UPS shut down, SCR damaged no hazards. Charge voltage: 227V , Output voltage: 0V. UPS shut down, fuse F1 opened, IGBT module of A phase damaged no hazards. Charge voltage: 227V, Output voltage: 0V. UPS shut down, fuse F1 opened, IGBT module of A phase damaged no hazards. Charge voltage: 227V, Output voltage: 0V.

Does ups overbalance if tilted to 10 degree?

Adequate protection against risk of fire, electric shock, injury to persons and hazardous energy level. All models of the UPS do not overbalance when tilted to an angle of 10 degree. Test force (N) . . . . . Complies with the requirement also after tests described below are applied. 2.10.4/RD.

Does ups have a safety interlock?

UPS with declared  $I_{cw}$  not exceeding 10kA. (No safety interlock provided for operator protection since there are no liable hazards capable of harming the operator during operation). No safety interlocks. related circuits . . . . . See below.

## EAST uninterruptible power supply ups standard

---



**??????? (UPS) ???????(? 2034  
?)?**

Aug 12, 2025 · Rotary Uninterruptible Power Supply (UPS) Market is anticipated to expand from \$0.8 Billion in 2024 to \$1.3 Billion by 2034, growing at a CAGR of approximately 5%. The ...

---

## Contact Us

For catalog requests, pricing, or partnerships, please visit:  
<https://institut3i.fr>